



# Certificate of Compliance

This certificate is issued for the following:

## Centrifugal Fire Pumps (Axial Split-Case Type)

Omega FXF 200-520, Omega FXF 200-670 and Omega FXF 250-600  
(see ratings attached)

### Prepared for:

KSB Aktiengesellschaft  
Johann-Klein-Straße 9  
Dept T-SP126-G  
D-67227 Frankenthal  
Germany

### Packaged at:

Kagama Industrieausrustungen GmbH  
Adsenser Str. 1  
30982 Pattensen  
Germany

FM Approvals Class: 1311

Approval Identification: 3056066      Approval Granted: May 16, 2017

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read "D. B. Fuller".

David B. Fuller  
AVP, Manager of Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062 USA

June 9, 2017

Date



*Member of the FM Global Group*



# Certificate of Compliance

Product	Rated Capacity, (gal/min)	Rated Capacity, (dm <sup>3</sup> /min)	Rated Net Head at Rated Capacity, psi	Rated Net Head at Rated Capacity, kPa	Rated Speed, r/min	Suction Inlet, dia., in.	Discharge Outlet, dia., in.	Stage(s)
Omega FXF 200-520	2000	7570	77-142	530-980	1480	10	8	1
Omega FXF 200-520	2500	9465	129	890	1480	10	8	1
Omega FXF 200-520	2000	7570	121-217	835-1495	1780	10	8	1
Omega FXF 200-520	2500	9465	110-202	760-1395	1780	10	8	1
Omega FXF 200-670	2000	7570	168-226	1160-1560	1480	10	8	1
Omega FXF 200-670	2500	9465	158-215	1090-1480	1480	10	8	1
Omega FXF 250-600	3000	11,360	102-179	705-1235	1480	12	10	1
Omega FXF 250-600	3500	13,250	122-170	840-1170	1480	12	10	1



*Member of the FM Global Group*